

Illinois Department of Public Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: IL6007090	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 08/14/2015
NAME OF PROVIDER OR SUPPLIER PARIS HEALTH CARE CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 1011 NORTH MAIN STREET PARIS, IL 61944		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S9999	Final Observations STATEMENT OF LICENSURE VIOLATIONS: Section 300.7060 Environment a.) The environment (cultural, social, and physical) shall support the functioning of cognitively impaired residents. It shall accommodate behaviors, maximize functional abilities, promote safety, and encourage residents' independence by compensating for losses resulting from the disease process in accordance with each resident's care plan. This requirement is not met as evidenced by the following: Based on observation and interview, the facility failed to ensure that safe water temperatures were maintained in two central bathrooms. This has the potential to affect four residents (R4, R6, R15, and R21) in the sample of 15 and 22 residents (R8, R11, R25-44) in the supplemental sample. Findings include: On 8-12-2015 at 10:40 AM on the Alzheimer ' s Unit, the locked North common bathroom shower temperature measured 121 degrees Fahrenheit (F) using a calibrated thermometer. The water temperature at the adjacent hand sink in the bathroom shower measured 121 degrees F by thermometer. E1 (Housekeeping Director) acknowledged the temperature readings at both water sources. On 8-12-2015 at 11:36 AM on the Alzheimer ' s Unit, the locked South common bathroom shower temperature measured 128 degrees F by thermometer. The adjacent hand sink water temperature measured 128 degree F by	S9999		

Attachment A
Statement of Licensure Violations

Illinois Department of Public Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

09/03/15

Illinois Department of Public Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: IL6007090	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 08/14/2015
---	---	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

PARIS HEALTH CARE CENTER

1011 NORTH MAIN STREET

PARIS, IL 61944

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S9999	Continued From page 1 thermometer. On 8-12-2015 at 11:45 AM E1 (Housekeeping Director) stated that residents bathed in North common bathroom and South common bathroom showers on the Alzheimer ' s Unit. On 8-12-2015 at 1:30 PM, E2 (Maintenance Director) measured the water temperature at the North common bathroom hand sink with a facility thermometer and acknowledged the temperature was too high at 120 degrees F. Illinois Department of Public Health (IDPH) thermometer measured 120 degrees F at the same hand sink. E2 then measured the shower temperature at 134 degree F. E2 then stated " there is something going on ". IDPH thermometer measured 134 degree F at the same shower. On 8-12-2015 at 1:37 PM on the Alzheimer ' s Unit, E2 measured the North common bathroom hand sink temperature at 128 degrees F. IDPH thermometer measured 128 degrees F on the same hand sink. The resident census for 8-12-15 documents R4, R6, R8, R11, R15, R21, and R25-44 residing at the facility. (B)	S9999		